



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Certificate No.: CE240303008944

Product	Moulded Case Circuit Breaker
Applicant	Zhejiang CHINT Electrics Co., Ltd. No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang Province, P.R.China
Type/Model	NXM-W800S、H, NXMH-W800S、H, NXMP-W800S、H, NXMF-W800S、H, NXM-1000S、H, NXMH-1000S、H, NXMP-1000S、H, NXMF-1000S、H, NXMS-1000S、H, NXMSH-1000S、H, NXMSP-1000S、H, NXMSF-1000S、H
Technical data	See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2024CQC0303-014822, the submitted sample(s) of the above item complies with:

EN 60947-2:2017/A1:2020;EN 60947-2:2017

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only, and does not include the manufacturing process. Users shall affix the mark in accordance with the related legislation.

Valid from: Jun.13,2024

Valid until: Jun.12,2027

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE240303008944

NXM-W800S、H, NXMH-W800S、H, NXMP-W800S、H, NXMF-W800S、H,
NXM-1000S、H, NXMH-1000S、H, NXMP-1000S、H, NXMF-1000S、H,
NXMS-1000S、H, NXMSH-1000S、H, NXMSP-1000S、H, NXMSF-1000S、H;
Uimp:12kV;
Ui:1000V;
Ue:AC220V/AC230V/AC240V, AC380V/AC400V/AC415V, AC500V(only for type H),
AC660V/AC690V;
thermo-magnetic, electromagnetic:
In: 500A, 600A, 630A, 700A, 800A(NXM-W800S、H; NXMH-W800S、H; NXMP-W800S、
H; NXMF-W800S、H);
thermo-magnetic, electromagnetic:
In: 500A, 600A, 630A, 700A, 800A, 900A,1000A(NXM-1000S、H; NXMH-1000S、H;
NXMP-1000S、H; NXMF-1000S、H);
electronic:
In: 630A, 800A, 1000A(NXMS-1000S、H; NXMSH-1000S、H; NXMSP-1000S、H;
NXMSF-1000S、H);
Type of over-current release: thermo-magnetic, electromagnetic, electronic;
Icw:12kA/1s(only for electronic);
Ics:
Type S: (AC220V/AC230V/AC240V)/(AC380V/AC400V/AC415V)/(AC660V/AC690V):
Ics=50kA/36kA/13kA;
Type H:
(AC220V/AC230V/AC240V)/(AC380V/AC400V/AC415V)/AC500V/(AC660V/AC690V):
Ics=75kA/50kA/40kA/15kA;
Icu:
Type S: (AC220V/AC230V/AC240V)/(AC380V/AC400V/AC415V)/(AC660V/AC690V):
Icu=75kA/50kA/15kA;



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD. CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE240303008944

Type H:
(AC220V/AC230V/AC240V)/(AC380V/AC400V/AC415V)/AC500V/(AC660V/AC690V):
Icu=100kA/70kA/50kA/20kA;
Selectivity category: A (thermo-magnetic, electromagnetic), B (electronic);
Tripclass com.cqc.cms.component.word.CertiAnnexDataModel(applicable for motor protection):thermo-magnetic:20, 30; electronic:10A, 10, 20, 30;
Poles:3P, 3P+N (only for thermo-magnetic, electromagnetic 3 protected poles with an uninterrupted neutral pole), 4P(3 protected poles with a switched neutral pole), 4P;
Applicable for isolation(except 3P+N(3 protected poles with an uninterrupted neutral pole));
50Hz /60Hz
Auxiliary contacts:
1NO1NC, 2NO2NC;
Ith:6A;
AC-15:Ue/Ie:AC415V/400V/380V/0.4A;
DC-13:Ue/Ie:DC250V/220V,110V/0.2A;
Accessories with electronic circuits:
Motor-operator: MD-M5;
Us: AC220V/230V/240V, DC110V, DC220V/250V, AC380V/400V/415V
Undervoltage release: UVT-M6;
Us: AC220V/230V/240V, AC380V/400V/415V;



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE