



Ref. Certif. No.

SE-108293M3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Zhejiang Chint Electrics Co., Ltd.
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,
Zhejiang Province, P.R.China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Same as applicant

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See page 2

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NB1-63, NB1-63H

Additional information (if necessary may also be reported on page 2)

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

230100201SHA-001
230100201SHA-001M1

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 16 November, 2023

intertek

Signature:

Fredrik Wennersten

Ratings and principal characteristics

Ue= 110 or 230/400 or 240/415V~(1P), 230 or 240V~(1P+N), 110 or 400 or 415V~(2P), 400 or 415V~ (3P, 3P+N, 4P)

In= 1, 1.6, 2, 3, 4, 5, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A(30°C)

In= 1, 2, 3, 4, 6, 10, 16, 20, 25, 32, 40, 50, 63A(55°C)

Ics= 7500A, Icn=10000A (for NB1-63H)

Ics= Icn= 6000A (for NB1-63)

B-, C- & D- type, 50/60Hz, Energy limiting class 3.

Additional information

This certificate replaces previously issued certificate ref. No. SE-108293M2 dated 13 January 2023 for the same model. A new certificate has been issued on account of adding "110V~" to 1P and 2P.

Date: 16 November, 2023

Signature:

