

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC CONTACTOR

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing
City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing
City, Zhejiang Province, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

Zhejiang CHINT Electrics Co., Ltd.
No.2 Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone,
North Baixiang, Yueqing, Wenzhou, Zhejiang Province, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NC6-06、NC6-09

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-100360

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE


Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Apr.14,2022

Signature:



Xie ZhaoXu

CB 0064065

NC6-06,NC6-09

Uimp: 8kV;

Ui: 690V;

Ith: 20A;

NC6-06:

AC-1: Ue/Ie: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;

AC-3: Ue/Ie: AC220V/230V/6A, AC380V/400V/6A, AC660V/690V/3.8A;

AC-4: Ue/Ie: AC220V/230V/6A, AC380V/400V/6A, AC660V/690V/3.8A;

NC6-09:

AC-1: Ue/Ie: AC220V/230V/20A, AC380V/400V/20A, AC660V/690V/20A;

AC-3: Ue/Ie: AC220V/230V/9A, AC380V/400V/9A, AC660V/690V/5A;

AC-4: Ue/Ie: AC220V/230V/9A, AC380V/400V/9A, AC660V/690V/5A;

Us: AC24V,AC36V,AC42V,AC48V,AC110V,AC120V,AC127V,AC 220V,AC230V,
AC240V,AC270V,AC380V,AC400V,AC415V(50Hz,50/60Hz,60Hz);

3P,4P;

Auxiliary contact:

1NO,1NC;

Ith: 10A;

AC-15: Ue/Ie: AC380V/400V/0.95A;

DC-13: Ue/Ie: DC220V/250V/0.15A

Page 1 of 2

Additional information (if necessary)

Date:

Apr.14,2022

Signature:



Xie ZhaoXu

Description of Sample Type:

NC 6- □ □ □ □

Type and number of contacts, expressed in numbers

10:3NO(Main),1NO(Auxiliary)

01:3NO(Main),1NC(Auxiliary)

04:4NO(Main)

08:2NO2NC(Main)

Basic specification code,
rated operational current(380/400V,AC-3)

Design serial number

AC contactor

Enterprise characteristic code

Page 2 of 2

Additional information (if necessary)

Date:

Apr.14,2022

Signature:

谢肇煦

Xie ZhaoXu