

IEC

IECEE



TM

Ref. Certif. No.

CN60185

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC Contactor

Name and address of the applicant

Zhejiang CHINT Electronics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing
City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electronics Co., Ltd.
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang Town, Yueqing
City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electronics Co., Ltd.
No.2, Changjiang Road, CHINT Intelligent Electric Appliance Industrial Zone,
North Baixiang, Yueqing, Zhejiang Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NC8-40/□□/□, NC8-50/□□/□, NC8-65/□□/□,
NC8-40/□□/□/□, NC8-50/□□/□/□, NC8-65/□□/□/□;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-105236

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jun.20,2023

Signature:

谢肇煦

Xie ZhaoXu

CB 0073302

NC8-40/□□/□, NC8-50/□□/□, NC8-65/□□/□,

NC8-40/□□/□/N, NC8-50/□□/□/N, NC8-65/□□/□/N;

Uimp: 8kV;

Ui: 690V;

Ue: AC220V/230V/240V, AC380V/400V/415V, AC660V/690V;

NC8-40/□□/□, NC8-40/□□/□/N:

Ith: 60A;

AC-1: Ue/Ie: AC220V/230V/240V/60A, AC380V/400V/415V/60A, AC660V/690V/60A;

AC-3: Ue/Ie: AC220V/230V/240V/40A, AC380V/400V/415V/40A, AC660V/690V/34A;

AC-4: Ue/Ie: AC220V/230V/240V/40A, AC380V/400V/415V/40A, AC660V/690V/34A

(NC8-40, NC8-40/W, NC8-40/Z, NC8-40/4/Z);

AC-4: Ue/Ie: AC220V/230V/240V//18.5A, AC380V/400V/415V/18.5A, AC660V/690V/9A;

(NC8-40/4, NC8-40/22, NC8-40/4/W, NC8-40/22/W);

NC8-50/□□/□, NC8-50/□□/□/N:

Ith: 80A;

AC-1: Ue/Ie: AC220V/230V/240V/80A, AC380V/400V/415V/80A, AC660V/690V/80A;

AC-3: Ue/Ie: AC220V/230V/240V/50A, AC380V/400V/415V/50A, AC660V/690V/39A;

AC-4: Ue/Ie: AC220V/230V/240V/50A, AC380V/400V/415V/50A, AC660V/690V/39A

(NC8-50, NC8-50/W, NC8-50/Z, NC8-50/4/Z);

AC-4: Ue/Ie: AC220V/230V/240V/24A, AC380V/400V/415V/24A, AC660V/690V/12A;

(NC8-50/4, NC8-50/22, NC8-50/4/W, NC8-50/22/W);

NC8-65/□□/□, NC8-65/□□/□/N:

Ith: 80A;

AC-1: Ue/Ie: AC220V/230V/240V/80A, AC380V/400V/415V/80A, AC660V/690V/80A;

AC-3: Ue/Ie: AC220V/230V/240V/65A, AC380V/400V/415V/65A, AC660V/690V/42A;

AC-4: Ue/Ie: AC220V/230V/240V/65A, AC380V/400V/415V/65A, AC660V/690V/42A

(NC8-65, NC8-65/W, NC8-65/Z, NC8-65/4/Z);

AC-4: Ue/Ie: AC220V/230V/240V/28A, AC380V/400V/415V/28A, AC660V/690V/14A

(NC8-65/4, NC8-65/22, NC8-65/4/W, NC8-65/22/W);

Page 1 of 2

Additional information (if necessary)

Date: Jun.20,2023

Signature:

谢肇煦

Xie ZhaoXu

Us:

NC8-40~65,NC8-40/4~65/4,NC8-40/22~65/22:

AC24V,36V,42V,48V,110V,120V,127V,220V,230V,240V,277V,380V,400V,415V,440V,460V,480V,600V,660V; 50/60Hz, 50Hz;

NC8-40/W~65/W,NC8-40/4/W~65/4/W,NC8-40/22/W~65/22/W:

AC/DC 100V-250V,48V-130V,24V-60V;

NC8-40/Z~65/Z: DC: 24V,48V,110V,120V,125V,220V, 3P;

NC8-40/4/Z~65/4/Z: DC: 24V,48V,110V,220V, 4P

3P,4P;

IP: NC8-40-65,NC8-40/W-65/W,NC8-40/Z~65Z,NC8-40/4/Z~65/4/Z: IP20(only for front side),

NC8-40/4-65/4,NC8-40/22-65/22,NC8-40/4/W-65/4/W,NC8-40/22/W-65/22/W: IP10;

Auxiliary contacts:

1NO+1NC;

Ith: 10A;

AC-15: Ue/Ie: AC380V/400V/415V/1.5A;

DC-13: Ue/Ie: DC220V/250V/0.3A;

Page 2 of 2

Additional information (if necessary)

Date: Jun.20,2023

Signature:

谢肇煦

Xie ZhaoXu